

# PRODUCT CONFORMITY CERTIFICATE

This is to certify that the

## O2000 Oxygen Analyser

Manufactured by:

**Opsis AB**  
P.O. Box 244  
S-244 02 Furulund  
Sweden


has been assessed by CSA Group  
and for the conditions stated on this certificate complies with:

**Environment Agency Guidance**  
**“MCERTS for stack emissions monitoring equipment at industrial installations”**  
- **Continuous emissions monitoring systems (CEMS)**  
**Updated 28 August 2024**  
**EN 15267-1:2023, EN15267-2:2023, EN 15267-3:2007**  
**& QAL 1 as defined in EN 14181: 2014**

Certification range:

O<sub>2</sub> 0 to 25 %vol

Project number: 80287225  
Certificate number: CSA MC020012/07  
Initial certification: 01 March 2002  
This certificate issued: 23 March 2026  
Renewal date: 28 March 2031



Andrew Young  
Environmental Team Manager

MCERTS is operated on behalf of the Environment Agency by

## **CSA Group Testing UK Ltd**

Unit 6, Hawarden Industrial Park  
Hawarden, Deeside, CH5 3US  
Tel: +44 (0)1244 670 900



0011

*The MCERTS certificate consists of this document in its entirety.  
For conditions of use, please consider all the information within.  
This certificate may only be reproduced in its entirety and without change  
To authenticate the validity of this certificate please visit [www.csagroupuk.org/mcerts](http://www.csagroupuk.org/mcerts)*

## Certificate Contents

Approved Site Application.....	2
Basis of Certification .....	2
Product Certified.....	2
Certified Performance .....	3
Description.....	6
General Notes .....	6

## Approved Site Application

Any potential user should make sure, in consultation with the manufacturer, that the monitoring system is suitable for the intended application. For further information on stack emissions monitoring refer to the Environment Agency's guidance available at [www.mcerts.net](http://www.mcerts.net)

This instrument is considered suitable for use on waste incineration and large combustion plant applications. This CEMS has been proven suitable for its measuring task (parameter and composition of the flue gas) by use of the QAL 1 procedure specified in EN14181. The lowest certified range shall not be more than 1.5 times the daily average emission limit value (ELV) for incineration plants, and not more than 2.5 times the ELV for other types of applications.

The field test was performed using two complete measuring systems over a total period of six months in the waste gas of a waste incineration plant.

## Basis of Certification

This certification is based on the following test report(s) and on CSA Group's assessment and ongoing surveillance of the product and the manufacturing process:

TÜV Rheinland report 936/808017/A dated 8/02/1999  
Sira Report N 0394 dated February 2002

TÜV Rheinland report 936/21213004/B dated 13/09/2010  
Sira Evaluation Report 16A24051 (O2000) dated 25/01/11

## Product Certified

The O2000 Oxygen Analyser measuring system consists of the following parts:

- Sample probe (Model 502) with an in-situ sensor
- O2000 monitor unit

This certificate applies to all instruments fitted with software version 2.51 onwards (O2000 unit serial number 982115 onwards and Model 502 serial number 98111 onwards).

Certificate No: CSA MC020012/07  
This certificate issued: 23 March 2026

*This certificate may only be reproduced in its entirety and without change  
To authenticate the validity of this certificate please visit [www.csagroupuk.org/mcerts](http://www.csagroupuk.org/mcerts)*



Test	Results expressed as % volume fraction				Other results	MCERTS specification
	<0.5	<1	<2	<5		
Cross-sensitivity at zero with interferents: O <sub>2</sub> , H <sub>2</sub> O, CO, CO <sub>2</sub> , CH <sub>4</sub> , N <sub>2</sub> O, NO, NO <sub>2</sub> , NH <sub>3</sub> , SO <sub>2</sub> , HCl O <sub>2</sub>	0.00					<0.4%
Cross-sensitivity at reference with interferents: O <sub>2</sub> , H <sub>2</sub> O, CO, CO <sub>2</sub> , CH <sub>4</sub> , N <sub>2</sub> O, NO, NO <sub>2</sub> , NH <sub>3</sub> , SO <sub>2</sub> , HCl O <sub>2</sub>	0.00					<0.4%
Excursion of measurement beam of cross-stack in-situ CEMS O <sub>2</sub>					N/A	<2.0%
Converter Efficiency					N/A	>95%
Measurement uncertainty O <sub>2</sub>					4.8%	<7.5%
Calibration function (field) O <sub>2</sub>					>0.9320	>0.90
Response time (field) O <sub>2</sub>					32s Note 1	<200s
Lack of fit (field) O <sub>2</sub>					<0.2% Note 2	<0.2%
Maintenance interval O <sub>2</sub>					4-weeks	>8 days
Zero and Span drift requirement	The CEM does not contain an automatic correction of zero and span drift.					Clause 6.13 & 10.13  Manufacturer shall provide a description of the technique to determine and compensate for zero and span drift.

Certificate No: CSA MC020012/07  
 This certificate issued: 23 March 2026

*This certificate may only be reproduced in its entirety and without change  
 To authenticate the validity of this certificate please visit [www.csagroupuk.org/mcerts](http://www.csagroupuk.org/mcerts)*

Test	Results expressed as % volume fraction				Other results	MCERTS specification
	<0.5	<1	<2	<5		
Change in zero point over maintenance interval O <sub>2</sub>	0.04				Note 3	<0.2%
Change in reference point over maintenance interval O <sub>2</sub>	-0.15				Note 3	<0.2%
Availability O <sub>2</sub>					>99.6%	>98%
Reproducibility O <sub>2</sub>	0.10					<0.2%

For the recertification, no additional field test has been performed. The field test data has been taken from the TÜV report No. 936/8080017/A, dated 8/02/1999. This test data has been recalculated according to the requirements of EN 15267-3. For the original field test, the system was evaluated for 11 months on a municipal waste incinerator. The system was evaluated for 9 weeks mounted on a coal fired power station with particulate abatement.

- Note 1: Based on laboratory response time test. The response time in the field must be verified during every check of installation of the CEM.
- Note 2: Based on field calibration function test and laboratory lack of fit test. The lack of fit in the field must be verified during every check of installation of the CEM.
- Note 3: Based on original certification.

Certificate No: CSA MC020012/07  
 This certificate issued: 23 March 2026

*This certificate may only be reproduced in its entirety and without change  
 To authenticate the validity of this certificate please visit [www.csagroupuk.org/mcerts](http://www.csagroupuk.org/mcerts)*

## Description

The system continuously measures O<sub>2</sub> in flue gas. The system comprises two components, a sample probe (Model 502) with an in-situ sensor and a control unit.

The zirconia sensor within the probe is controlled at about 700°C by an integral heated. This gives a Nernstian response to the ratio of the reference and measured partial pressure of O<sub>2</sub> across the sensor. A source of reference air is required for the probe.

This certificate applies only to a complete O2000 system. It does not apply to individual components.

## General Notes

1. This certificate is based upon the equipment tested. The Manufacturer is responsible for ensuring that on-going production complies with the standard(s) and performance criteria defined in this certificate. The manufacturer is required to maintain an approved quality management system controlling the manufacture of the certified product. Both the product and the quality management system shall be subject to regular surveillance according to 'Regulations Applicable to the Holders of CSA Group Testing UK Ltd Certificates'.
2. The design of the product certified is held and maintained by TÜV Rheinland for certificate No. CSA MC020012.
3. If a certified product is found not to comply, CSA Group should be notified immediately at the address shown on this certificate.
4. The certification marks that can be applied to the product or used in publicity material are defined in 'Regulations Applicable to the Holders of CSA Group Testing UK Ltd Certificates'.
5. This document remains the property of CSA Group and shall be returned when requested by CSA Group.

Certificate No: CSA MC020012/07  
This certificate issued: 23 March 2026

*This certificate may only be reproduced in its entirety and without change  
To authenticate the validity of this certificate please visit [www.csagroupuk.org/mcerts](http://www.csagroupuk.org/mcerts)*